



TECHNICKÝ A ZKUŠEBNÍ ÚSTAV STAVEBNÍ PRAHA, s.p.
Technical and Test Institute for Construction Prague, SOE

Akreditovaná zkušební laboratoř, Autorizovaná osoba, Notifikovaná osoba, Oznamovaný subjekt, Subjekt pro technické posuzování, Certifikační orgán, Inspekční orgán • Accredited Testing Laboratory, Authorized Body, Notified Body, Technical Assessment Body, Certification Body, Inspection Body • Prosecká 811/76a, 190 00 Praha 9 - Prosek, Czech Republic

Branch 0300 – Pilsen

CERTIFICATE

No. 030 – 058714

About the qualities of a product

Certified quality: Properties according to the following test procedures:

EN ISO 10545-4:2014: Ceramic tiles – Part 4: Determination of modulus of rupture and breaking strength
EN ISO 10545-12:2002 Ceramic tiles – Part 12: Determination of frost resistance
EN ISO 10545-15:1998 Ceramic tiles – Part 15: Determination of lead and cadmium given off glazed tiles
PCEN/TS 16165:2013 Determination of slip resistance of pedestrian surfaces

Product: Ceramic tiles declaration: EN 14411: 2017 ed. 3, dry-pressed, Group Bla, Annex G
Producer: LLC «Samarskij Stroyfarfor» 443528, Samara region, Volzhsky district, Stroykeramika settlement, Russian Federation

Order: Z030 19 0204

Achieved values:


Main characteristics	Results	Requirements EN 14 411 ed.3: 2017
Determination of frost resistance EN ISO 10545-12:2002	satisfies 100 freeze-thaw cycles without visible changes under the following conditions: 15 minutes at -5 ° C and 15 minutes at + 5 ° C.	product resistant
Breaking strength EN ISO 10545-4:2014	2940 N	min. 1300 N
Modulus of rupture EN ISO 10545-4:2014	50,2 N/mm ²	Individually min. 32 N/mm ² average min. 35 N/mm ²
Determination of lead and cadmium given off by glazed tiles EN ISO 10545-15:1998	Release of cadmium max. 0,0008mg/dm ² Release of lead max. 0,0054 mg/dm ²	Release of cadmium max. 0,07mg/dm ² Release of lead max. 0,8 mg/dm ²
Slip resistance PCEN/TS 16165:2013	according to the declaration	according to the declaration

The certificate is issued on the basis of the results of the tests stated in report no. 030-058713 from 19th July 2019.

Number of pages of certificate: 1

Certificate validity: till 31st August 2022

The certificate can be cancelled upon finding non-adherence to the certified parameters of product qualities.



Pizeň 19th July 2019

Stamp of TZUS – branch Pilsen


Ing. Alexander Trinner
Branch Director

Warning: Without a written consent of the representative of the head of the authorised person, this report must not reproduced otherwise than in its entirety.

Technical and testing construction institute Prague, state enterprise, branch 0300 -
☎: +420 377 243 331, Fax: +420 377 244 158,

Pilsen, Zahradní 15, 326 00 Pilsen, Czech Republic
✉ e-mail: kotorova@tzus.cz, www.tzus.cz
Id. No.: 000 15679 Tax Co. Id. No.: CZ-00015679